

Backup Time Table for Custos Series 1.0 kVA UPS

UPS Type	Battery		Backup Time (in min.)			
			100%	75%	50%	25%
Custos 1KVA	UPS with internal batteries (2 x 9Ah batteries)	Backup Time	3.8	6	10,5	24
MPF0005500GP	+ 1x(4 x 24V/9Ah Batteries)	Backup Time	168	78	52	37

Backup Time Table for Custos Series 2.0 kVA UPS

UPS Type	Battery Box		Backup Time with Load (Min)			
			100%	75%	50%	25%
Custos 2KVA	UPS with internal batteries (4 x 9Ah batteries)		4	6,1	11	26
MPF0005600GP	+ 1x (8 x 48V/9Ah Batteries)	Backup Time	20	29	47	98
MPF0005600GP	+ 2x (8 x 48V/9Ah Batteries)	Backup Time	38	54	88	181

Backup Time Table for Custos Series 3.0 kVA UPS

UPS Type	Battery Box		Backup Time with Load (Min)			
			100%	75%	50%	25%
Custos 3KVA	UPS with internal batteries (6 x 9Ah batteries)		4	6,3	11,5	28
MPF0005700GP	+ 1x (12 x 72V/9Ah Batteries)	Backup Time	20,5	30	48	107
MPF0005700GP	+ 2x (12 x 72V/9Ah Batteries)	Backup Time	39	55	91	197